Air Monitoring Fieldsheet

SLS ENV PTY LTD

Client	PAYNTERS	**Job Number**	201-89-001	**Sample Date**	30/08/2021
Contact	Colin Balderson0437 003 316	**Site**	201-89- PAYNTERS - Rockhampton Girls Grammar 4700	**Sampled By**	Sylvia Kaiki
			Removal of ACM ceiling sheets Approximately 120m2	**Sample Type**	Exposure /Control
				Analysed By:	Sylvia Kaiki
Phone				**Analysis Date:**	30/08/2021

3	Phase	Location	Cassette	Pump	Airflow On (mL/min)	Airflow Off (mL/min)	Airflow Avg (mL/min)	Time On	Time Off	Time (mins)	Volume (L)	Fields	Fibres	Conc. (fb/mL)
SLS001	WIP	External of classroom north elevation of removal area	SLS001	SLS01	1.0	1.0	1.0	07:00	14:00	120	360	100	0	<0.01
SLS002	WIP	External adjacent to truck..	SLS002	SLS02	1.0	1.0	1.0	07:01	14:01	120	360	100	0	<0.01
SLS003	CL	Internal of building	SLS003	SLS03	3.0	3.0	3.0	12:00	14:00	120	360	100	0	<0.01
SLS004	BL		SLSOO4									100	0	<0.01